

TABLE 4 – Indicative testing and inspection intervals for electrical equipment
(CAUTION: This page must be read in conjunction with AS/NZS 3760 as a whole, and particularly 2.1)

Type of environment and/or equipment	Interval between inspection and tests					
	Equipment including Class I equipment, Class II equipment, cord sets, cord extension sets and EPODs (a)	Residual current devices (RCDs)				Fixed (f)
		Push-button test – by user		Operating time and push-button test		
(a)	(b)	Portable (c)	Fixed (d)	Portable (e)	Fixed (f)	
1 Factories, workshops, places of manufacture, assembly, maintenance or fabrication	6 months	Daily, or before every use, whichever is the longer	6 months	12 months	12 months	
2 Environment where the equipment or supply flexible cord is subject to flexing in normal use OR is open to abuse OR is in a hostile environment	12 months	3 months	6 months	12 months	12 months	
3 Environment where the equipment or supply cord is NOT subject to flexing in normal use and is NOT open to abuse and is NOT in a hostile environment	5 years	3 months	6 months	2 years	2 years	

Type of environment and/or equipment	Interval between inspection and tests					
	Equipment including Class I equipment, Class II equipment, cord sets, cord extension sets and EPODs (b)	Residual current devices (RCDs)				Fixed (f)
		Push-button test – by user		Operating time and push-button test		
(a)	(c)	(d)	(e)	(f)	(f)	
4 Residential type areas of: hotels, residential institutions, motels, boarding houses, halls, hostels accommodation houses, and the like	2 years	6 months	6 months	2 years	2 years	
5 Equipment used for commercial cleaning	6 months	N/A	Daily, or before every use, whichever is the longer	6 months	N/A	
6 Hire equipment: Inspection	Prior to hire	Including push-button test by hirer prior to hire		N/A	N/A	
Test and tag	3 months	N/A	3 months	12 months		
7 Repaired, serviced and second-hand equipment	After repair or service which could affect electrical safety, or on reintroduction to service, refer to AS/NZS 5762.					